

HOUSING AUTHORITY OF THE COUNTY OF STANISLAUS

1701 Robertson Road P.O. Box 581918 Phone (209) 557-2000
Modesto, California 95358-0033

BID ADDENDUM #1

HVAC Replacement CA026017-A

Bid # 10901

Bid Date and Time: February 24, 2010 at 2:15 PM

This form serves as notice to bidders that there has been a change made to the invitation for bids for the above mentioned bid number. Changes include clarification to the specifications as follows:

1. HVAC Equipment Specifications: The first two sentences of the first paragraph in this section of the specifications have been changed to clarify the number and sizes of the equipment. All other equipment specifications remain the same.
The units will be split systems with 2 or 3 tons nominal cooling capacity and 60,000 BTU heating input. Provide 12 two ton units and 25 three ton units as indicated on the unit address list.
2. Refrigerant Line Sets: Where line sets will be run along the exterior of the buildings, they will be covered with sheet metal covers which are securely attached to the buildings. Covers shall be constructed of minimum 24 gauge galvanized sheet metal and painted to match the building color as closely as possible.
3. Existing Wood Equipment Stand/Return: All existing equipment stands/returns will be modified as needed to meet current code requirements. This modification may vary from removing the existing stand completely to lining the existing stand with sheet metal. Either method is acceptable providing installation meets with building department approval.

THIS FORM MUST BE SIGNED BY THE BIDDER AND SUBMITTED WITH THE BID.

Acknowledgement of receipt of addendum.

Signature

Date